

سطح مقطع	ساختمان	ضخامت عایق		ضخامت روکش	قطر نهایی ( تقریبی )		مقاومت الکتریکی	وزن کابل ( تقریبی )		بسته بندی	
		XLPE	PVC		XLPE	PVC		XLPE	PVC		
		mm			mm			Kg / Km			
mm <sup>2</sup>	N x mm			mm			Ω / Km			m	
3x50	19x1.83	1.0	1.4	1.8	24.2	25.8	0.641	694	841	500	1
3x70	19x2.17	1.1	1.4	1.9	27.7	28.9	0.443	916	1052	500	2
3x95	19x2.52	1.1	1.6	2.1	31.2	33.2	0.320	1209	1426	500	3
3x120	37x2.03	1.2	1.6	2.2	34.5	36.1	0.253	1486	1716	500	4
3x150	37x2.28	1.4	1.8	2.3	38.5	40.1	0.206	1840	2099	500	5
3x185	37x2.53	1.6	2.0	2.4	42.5	44.1	0.164	2216	2524	500	6
3x240	37x2.87	1.7	2.2	2.6	47.5	49.8	0.125	2862	3265	500	7
3x300	61x2.50	1.8	2.4	2.9	52.1	54.5	0.100	3536	3998	500	8
3x50/25	19x1.83+7x2.17	1.0+0.9	1.4+1.2	1.9	26.7	27.4	0.641	809	928	500	9
3x70/35	19x2.17+7x2.50	1.1+0.9	1.4+1.2	2.0	30.4	30.6	0.443	1064	1189	500	10
3x95/50	37x1.83+7x2.93	1.1+1.0	1.6+1.4	2.2	34.2	35.2	0.320	1421	1637	500	11
3x120/70	37x2.05+19x2.15	1.2+1.1	1.6+1.4	2.3	38.0	38.2	0.253	1769	1986	500	12
3x150/70	37x2.25+19x2.15	1.4+1.1	1.8+1.4	2.4	41.1	41.6	0.206	2102	2361	500	13
3x180/95	37x2.53+37x1.83	1.6+1.1	2.0+1.6	2.6	45.8	48.5	0.164	2619	2887	500	14
3x240/120	37x2.91+37x2.05	1.7+1.2	2.2+1.6	2.8	52	52.8	0.125	3340	3726	500	15
3x300/150	61x2.53+37x2.25	1.8+1.4	2.4+1.8	2.9	57.1	59.1	0.100	4119	4639	500	16
4x50	19x1.83	1.0	1.4	1.9	27.8	29.4	0.641	908	1093	500	17
4x70	19x2.17	1.1	1.4	2.1	32.2	33.4	0.443	1206	1403	500	18
4x95	19x2.52	1.1	1.6	2.2	35.3	37.3	0.320	1582	1884	500	19
4x120	37x2.03	1.2	1.6	2.3	40.0	41.6	0.253	1973	226	500	20
4x150	37x2.28	1.4	1.8	2.5	45.0	46.6	0.206	2428	2796	500	21
4x185	37x2.53	1.6	2.0	2.7	48.4	55.5	0.164	2929	3385	500	22
4x240	37x2.87	1.7	2.2	2.9	55.9	57.9	0.125	3799	4370	500	23
4x300	61x2.50	1.8	2.4	3.1	61.2	63.6	0.100	4701	5260	400	24